




1. Trykk på:  
**Setup**

2. Trykk på:  
**System**




3. Tast inn  
passord:  
**126407**,  
4. trykk:  
**Enter**  
**Password.**



6. Superuser skal vises  
her når man går inn  
igjen.ref pkt 5.

5. Trykk på **EXIT**  
knapp Gjenta punkt  
1 og 2, fortsettelse  
neste side



Trykk på flik: **Service**

## 9.1 Service

The system can monitor up to 24 service operations displaying for each one the date interval and/or the residual number of hours before action is required . These intervals are preset by service operator during system setup according engine manufacturer specification ( see xxx ). When date interval or number of hours is expired the unit raises an alarm with the description of the service being required.

Service operation description

Srv.1	Srv.2	Srv.3	Log
Oil E.S.	19/03/2013	299.9	Reset
Oil Filter E.S.	19/03/2013	299.9	Reset
Fuel Filter E.S.	28/01/2013	249.9	Reset
	--/--/----	0.0	Reset
	--/--/----	0.0	Reset
	--/--/----	0.0	Reset
	--/--/----	0.0	Reset
	--/--/----	0.0	Reset

<< >> Menu Exit

Service date interval

Service residual hours

Reset button

After the service operation has been performed the number of hours counter and date interval must be reset to original value by pressing the corresponding Reset button. The Service or Factory login allows to activate Reset buttons. The unit also records each reset operation with date time in a special log file.